



COMMONWEALTH of VIRGINIA

ROBERT B. STROUBE, M.D., M.P.H.
STATE HEALTH COMMISSIONER

Department of Health
P O BOX 2448
RICHMOND, VA 23218

TTY 7-1-1 OR
1-800-828-1120

June 15, 2007

Ms. Anastasia R. O'Hara
Sales Coordinator
Norwesco, Inc.
4365 Steiner Street
St. Bonifacius, MN 55375-0439

Dear Ms. O'Hara:

The Division of Onsite Sewage and Water Services (*Division*) has completed the review of the technical information you had submitted for the Norwesco's Rochester Rotational low profile polyethylene septic tanks for use in Virginia. The information is for 1050 gallon, 1250 gallon, and 1500 gallon, both single and dual compartment tanks.

Section 12 VAC 5-610-815 of the Sewage Handling and Disposal Regulations (*Regulations*) specifies the technical requirements for a septic tank. Technical details you submitted for the tanks indicate that some of the criteria for dimensions of the tanks are not in full compliance of the requirements specified in the *Regulations*. However, after reviewing the test reports prepared by the Universal Laboratory, Inc. and other supporting documents, the *Division* approves these tanks for use in Virginia if an NSF certified effluent filter is included in the outlet structure of each tank. This approval notice will be posted on the *Division's* web site as GMP #139.

This approval is in addition to the previously approved Norwesco septic tanks. Approval of these tanks does not constitute endorsement for use. The tanks approved must be installed and used in accordance with the requirements specified in the *Regulations*.

If you have any questions about this letter, you may call me at 804-864-7457.

Thank you,

Sincerely,

Anish R. Jantrania, Ph.D., P.E.
Technical Services Engineer.